



Certificate of Compliance

Certificate Number: LR 85680-1

Revision: LR 85680-15

Date Issued: January 28, 1999

Issued To: **JB Systems, Inc.**
10360-72nd St. N., Ste. 809
Largo, FL 33777
Attention: Mr. John M. Lawrence

The products listed below are eligible to bear the CSA Mark shown, with adjacent indicator NRTL/C.



Issued by: R.O. Cheyne, CET
Toronto, ON Canada

Signature: 

PRODUCTS

- CLASS 2632 01 - GAS BURNERS, ELECTRICAL EQUIPMENT FOR - Accessories
- CLASS 2632 81 - GAS BURNERS, ELECTRICAL EQUIPMENT FOR - Accessories - CERTIFIED TO U.S. STANDARDS
- CLASS 2642 01 - OIL BURNERS, ELECTRICAL EQUIPMENT FOR - Accessories
- CLASS 2642 81 - OIL BURNERS, ELECTRICAL EQUIPMENT FOR - Accessories - CERTIFIED TO U.S. STANDARDS

Flame monitors, 115/230V, 50/60Hz; output contacts 240V ac, 2A (non-ind), Iris, Models 300, 300HF, 6.2VA; 500, 18VA; Model 400, 115/230V, 50/60Hz, 5.6VA or 24V dc, 150mA; output contacts 240V ac, 2A (non-ind).

Flame detectors, infrared types, Models 300, S509, S511 and S512 and ultra violet types, Models S506, 400, for use with the above flame monitors.

Note: These flame monitors and detectors are Certified as component controls only.

APPLICABLE REQUIREMENTS

- | | | | |
|-------------------|---------|---|---|
| CAN/CSA-C22.2 No. | 199-M89 | - | Combustion Safety Controls and Solid-State Igniters for Gas and Oil Burning Equipment |
| UL Std No. | 372 | - | Primary Safety Controls for Gas- and Oil-Fired Appliances |

The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.